



# Washington Yu Ying PCS - Lead in Water Test Results



## FY20 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Washington Yu Ying PCS	WS-066-003	Break Room	3	In staff lounge 314			WF-072019-066003-03	10/11/2019	FT-FY20-072019-066003-A	<1	FT-FY20-072019-066003-B	<1
Washington Yu Ying PCS	WS-066-004	Cooler	3	In hallway adjacent to room 313	High	Left	WF-072019-066004-03	10/11/2019	FT-FY20-072019-066004-A	<1	FT-FY20-072019-066004-B	<1
Washington Yu Ying PCS	WS-066-005	Cooler	3	In hallway adjacent to room 313	Low	Right	WF-072019-066005-03	10/11/2019	FT-FY20-072019-066005-A	<1	FT-FY20-072019-066005-B	<1
Washington Yu Ying PCS	WS-066-006	Classroom Faucet	2	In classroom 207			WF-072019-066006-03	10/11/2019	FT-FY20-072019-066006-A	<1	FT-FY20-072019-066006-B	<1
Washington Yu Ying PCS	WS-066-007	Classroom Faucet	2	In classroom 205			WF-072019-066007-03	10/11/2019	FT-FY20-072019-066007-A	<1	FT-FY20-072019-066007-B	<1
Washington Yu Ying PCS	WS-066-008	Cooler	2	In hallway across from room 212	High	Left	WF-072019-066008-03	10/11/2019	FT-FY20-072019-066008-A	<1	FT-FY20-072019-066008-B	<1
Washington Yu Ying PCS	WS-066-009	Cooler	2	In hallway across from room 212	Low	Right	WF-072019-066009-03	10/11/2019	FT-FY20-072019-066009-A	<1	FT-FY20-072019-066009-B	<1
Washington Yu Ying PCS	WS-066-010	Classroom Faucet	2	In classroom 212			WF-072019-066010-03	10/11/2019	FT-FY20-072019-066010-A	<1	FT-FY20-072019-066010-B	<1
Washington Yu Ying PCS	WS-066-011	Classroom Faucet	2	In classroom 216			WF-072019-066011-03	10/11/2019	FT-FY20-072019-066011-A	<1	FT-FY20-072019-066011-B	<1
Washington Yu Ying PCS	WS-066-012	Classroom Faucet	2	In classroom 222			WF-072019-066012-02	10/11/2019	FT-FY20-072019-066012-A	<1	FT-FY20-072019-066012-B	<1
Washington Yu Ying PCS	WS-066-013	Classroom Faucet	2	In classroom 220			WF-072019-066013-02	10/11/2019	FT-FY20-072019-066013-A	<1	FT-FY20-072019-066013-B	<1
Washington Yu Ying PCS	WS-066-014	Cooler	1	In hallway across from room 129			WF-072019-066014-03	10/11/2019	FT-FY20-072019-066014-A	<1	FT-FY20-072019-066014-B	<1
Washington Yu Ying PCS	WS-066-015	Classroom Faucet	1	In classroom 129			WF-072019-066015-03	10/11/2019	FT-FY20-072019-066015-A	<1	FT-FY20-072019-066015-B	<1
Washington Yu Ying PCS	WS-066-016	Food Prep Sink	1	In kitchen 126			WF-072019-066016-03	10/11/2019	FT-FY20-072019-066016-A	1.2	FT-FY20-072019-066016-B	<1
Washington Yu Ying PCS	WS-066-017	Cooler	1	In hallway across from room 118	High	Left	WF-072019-066017-03	10/11/2019	FT-FY20-072019-066017-A	<1	FT-FY20-072019-066017-B	<1
Washington Yu Ying PCS	WS-066-018	Cooler	1	In hallway across from room 118	Low	Right	WF-072019-066018-03	10/11/2019	FT-FY20-072019-066018-A	<1	FT-FY20-072019-066018-B	<1
Washington Yu Ying PCS	WS-066-019	Health Suite	1	In health suite 116			WF-072019-066019-03	10/11/2019	FT-FY20-072019-066019-A	<1	FT-FY20-072019-066019-B	<1
Washington Yu Ying PCS	WS-066-020	Classroom Faucet	1	In classroom 118			WF-072019-066020-03	10/11/2019	FT-FY20-072019-066020-A	<1	FT-FY20-072019-066020-B	<1
Washington Yu Ying PCS	WS-066-021	Classroom Faucet	1	In classroom 107			WF-072019-066021-03	10/11/2019	FT-FY20-072019-066021-A	<1	FT-FY20-072019-066021-B	<1
Washington Yu Ying PCS	WS-066-022	Classroom Faucet	1	In classroom 109			WF-072019-066022-03	10/11/2019	FT-FY20-072019-066022-A	<1	FT-FY20-072019-066022-B	<1
Washington Yu Ying PCS	WS-066-023	Bottle Filler	4	In hallway adjacent to room 410			WF-072019-066023-02	10/11/2019	FT-FY20-072019-066023-A	<1	FT-FY20-072019-066023-B	<1
Washington Yu Ying PCS	WS-066-024	Cooler	4	In hallway adjacent to room 410	High	Left	WF-072019-066024-02	10/11/2019	FT-FY20-072019-066024-A	<1	FT-FY20-072019-066024-B	<1
Washington Yu Ying PCS	WS-066-025	Cooler	4	In hallway adjacent to room 410	Low	Right	WF-072019-066025-02	10/11/2019	FT-FY20-072019-066025-A	<1	FT-FY20-072019-066025-B	<1
Washington Yu Ying PCS	WS-066-026	Bottle Filler	1	In classroom 107			WF-072019-066026-02	10/11/2019	FT-FY20-072019-066026-A	<1	FT-FY20-072019-066026-B	<1
Washington Yu Ying PCS	WS-066-027	Bottle Filler	1	In classroom 109			WF-072019-066027-02	10/11/2019	FT-FY20-072019-066027-A	<1	FT-FY20-072019-066027-B	<1
Washington Yu Ying PCS	WS-066-028	Bottle Filler	1	In classroom 118			WF-072019-066028-02	10/11/2019	FT-FY20-072019-066028-A	<1	FT-FY20-072019-066028-B	<1
Washington Yu Ying PCS	WS-066-029	Bottle Filler	1	In classroom 129			WF-072019-066029-02	10/11/2019	FT-FY20-072019-066029-A	<1	FT-FY20-072019-066029-B	<1
Washington Yu Ying PCS	WS-066-030	Bottle Filler	2	In classroom 205			WF-072019-066030-02	10/11/2019	FT-FY20-072019-066030-A	<1	FT-FY20-072019-066030-B	<1
Washington Yu Ying PCS	WS-066-031	Bottle Filler	2	In classroom 207			WF-072019-066031-02	10/11/2019	FT-FY20-072019-066031-A	<1	FT-FY20-072019-066031-B	<1
Washington Yu Ying PCS	WS-066-032	Bottle Filler	2	In classroom 212			WF-072019-066032-02	10/11/2019	FT-FY20-072019-066032-A	<1	FT-FY20-072019-066032-B	<1
Washington Yu Ying PCS	WS-066-033	Bottle Filler	2	In classroom 216			WF-072019-066033-02	10/11/2019	FT-FY20-072019-066033-A	<1	FT-FY20-072019-066033-B	<1
Washington Yu Ying PCS	WS-066-034	Bottle Filler	2	In classroom 220			WF-072019-066034-02	10/11/2019	FT-FY20-072019-066034-A	<1	FT-FY20-072019-066034-B	<1
Washington Yu Ying PCS	WS-066-035	Bottle Filler	2	In classroom 222			WF-072019-066035-02	10/11/2019	FT-FY20-072019-066035-A	<1	FT-FY20-072019-066035-B	<1